Required Separation Distances for Well Siting per RCSA Section 19-13-B51d

Pollution Source	Separating Distance in Feet		
	< 10 gpm	<mark>10-50 gpm</mark>	>50 gpm
Subsurface Sewage System	75	150	200
Sanitary Sewer	75/25	150/75	200/100
Storm Drain	25	50	50
Foundation, Floor Drain	25	50	50
Dry Well	50	50	50
Annual High Water Mark (surface water body)	25	50	50
Liquid Fuel Storage Tanks & Piping	75	150	200
Underground Gaseous Fuel Storage Tanks &	25	25	25
Piping			
Other			

DPH Drinking Water Section