Aquarion Water Company PFAS Sampling Results

Cedar Heights System Results

All Results Reported as parts per trillion (ppt)

				Effective 6/15/22		Effective 6/15/22		Effective 6/15/22		Effective 6/15/22
				CT DPH		CT DPH		CT DPH		CT DPH
				PFOA		PFOS		PFHxS		PFNA
Water System Name	Sample Location	Test Date	PFOA	Action Level	PFOS	Action Level	PFHxS	Action Level	PFNA	Action Level
Cedar Heights	Cedar Heights Wells, POE	Jul. 2019	9		10		5		ND	
	Cedar Heights Wells, POE	Feb. 2020	11		11		5		ND	
	Cedar Heights Wells, POE	Aug. 2020	8		8		5		ND	
	Cedar Heights Wells, POE	Oct. 2020	11		13		8		ND	
	Cedar Heights Wells, POE	Feb. 2021	10		11		4		ND	
	Cedar Heights Wells, POE	Jun. 2021	10		11		6		ND	
	Cedar Heights Wells, POE	Aug. 2021	10		11		4		ND	
	Cedar Heights Wells, POE	Apr. 2022	9	16	10	10	4	49	ND	12
	Cedars Well, POE	Jul. 2019	9	16	9	" 10	4	45	ND	12
	Cedars Well, POE	Feb. 2020	12		10		5		ND	
	Cedars Well, POE	Aug. 2020	8		7		4		ND	
	Cedars Well, POE	Oct. 2020	9		9		3		ND	
	Cedars Well, POE	Feb. 2021	9		9		4		ND	
	Cedars Well, POE	Jun. 2021	10		10		4		ND	
	Cedars Well, POE	Aug. 2021	11		13		3		ND	
	Cedars Well, POE	Apr. 2022	12		10		3		ND	

Footnotes:

A yellow highlighted value denotes a historical concentration that is greater than the new Connecticut Department of Public Health Action Level established on June 15, 2022

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.

