

## Aquarion Water Company PFAS Sampling Results

**Town/City:** Plainville / Bristol / Farmington / Southington  
**Water System Name:** Plainville

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Johnson Ave Wells 3 & 6, POE	Dec. 2021	4		6		2		ND	
	Sep. 2022	5	16	5	10	3	49	ND	12
Woodford Ave Wells 2A & 7, POE	Dec. 2021	2		3		ND		ND	
	Sep. 2022	5	16	5	10	ND	49	ND	12

**Footnotes:**

\* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022.

**Definitions:**

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.