

## Aquarion Water Company PFAS Sampling Results

**Town/City: Stamford**  
**Water System Name: Stamford**

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Stamford Reservoirs, POE	Jun. 2019	4		ND		ND		ND	
	Jun. 2021	3		ND		ND		ND	
	Sep. 2022	3	16	ND	10	ND	49	ND	12
Woodway Road, Distribution Point	Aug. 2019	4		ND		ND		ND	
Wire Mill Well, POE - <b>NOT IN SERVICE</b>	–	–		–		–		–	

**Footnotes:**

\* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022.

**Definitions:**

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.