

**Aquarion Water Company of Massachusetts  
Historic PFAS Sampling Results**

**Water System Name: North Plymouth**

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	TOTAL PFAS6	Quarterly Average*	MassDEP MCL
North Plymouth	Well 1, (POE)	Oct. 2021	3.0	J	J	J	ND	ND	3.0	2.5	20
		Dec. 2021	2.1	ND	ND	ND	ND	ND	2.1		
		Jan. 2022	ND	ND	ND	ND	ND	ND	ND		
		Apr. 2022	2.2	J	J	ND	ND	ND	2.2		
	Well 2, (POE)	Mar. 2022	ND	ND	ND	ND	ND	ND	ND	ND	20
		Apr. 2022	ND	ND	ND	ND	ND	ND	ND	ND	20

**Footnotes:**

\*Compliance with the MCL is based on the quarterly average of all samples collected during the calendar quarter.

**Definitions:**

**J** -The result reported from the laboratory is below Minimum Reporting Level of 2 ppt, but greater than the Method Detection Limit. Per MassDEP, this value is not included in the compliance Total for PFAS6.

**MassDEP** - Massachusetts Department of Environmental Protection

**MCL** - Maximum Contaminant Level

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.